

Confidential Report

Client: HeartSine Technologies, Ltd. Canberra House 203 Airport Road West Belfast, BT3 9ED Northern Ireland <u>Att: Mr Allister McIntyre</u>	Test of: Samaritan PAD (Public Access Defibrillator) To: EN60601-1-2: 2002 & EN 55011: 1998 + A2: 2002 (Applicable Parts of)
---	---

COPIES TO: Files

REPORT REF: 07E2712-1

TESTED BY: Paul Reilly

DATE RECEIVED: June 2007

REPORT BY: Paul Reilly

ISSUE DATE: June 2007

APPROVED SIGNATORY: John McAuley

Compliance Engineering Ireland Ltd Terms and Conditions

1. All quotations are submitted, orders are accepted and services supplied by Compliance Engineering Ireland Limited ("CEIL") subject to and upon the following express Terms and Conditions and all other Conditions, warranties and representations express or implied and statutory or otherwise are hereby excluded insofar as it is lawful to do so. No addition thereto or variation therefrom, contained or referred to in the Customers order form or otherwise effected shall apply unless specifically agreed in writing by a duly Authorised Officer of CEIL.
2. All orders including any based on a quotation previously submitted by CEIL are subject to acceptance in writing by CEIL.
- 3.(a) The prices set out in any quotation are based upon current costs and if there is any variation in the said costs between the date of the order or Contract and delivery of the final report CEIL shall be entitled to adjust prices to reflect such variations.
- b) In the event of any suspension or variation of work arising from the Customer's instructions or lack of instructions the price set out in any quotation may be increased to cover any extra expense incurred by CEIL.
- c) All prices quoted are strictly NET. The customer shall where applicable, in addition to the relevant price, pay a sum equal to the VAT chargeable in respect of the supply of services.
- d) Accounts must be paid in full in advance or by way of an irrevocable letter of credit opened with a Bank approved by CEIL unless credit terms have been agreed by CEIL in which event accounts must be paid in full within 1 month from the date of the invoice. Time for payment is of the essence and the customer shall be liable to pay any outstanding amount from its due date until the date of payment at a rate of 2% per month or part thereof.
4. Any times quoted for the performance of services are to be treated as estimates only. CEIL shall not be liable in any manner whatsoever for failure to perform services within the time quoted, nor in such circumstances shall the Customer be entitled to cancel or terminate any order or contract.
5. The Customer is responsible for delivery to CEIL of test item(s) free of any duty, VAT, freight charges etc. unless otherwise agreed in writing by CEIL.
6. The Customer shall be responsible for collecting non-perishable samples received for testing or laboratory work upon completion of tests or laboratory work. If the Customer fails to collect such samples within 90 days from completion of the tests or laboratory work CEIL shall be entitled without further notice to dispose of the samples without liability.
7. No action or legal proceedings shall be taken (except in the case of wilful neglect or default) against CEIL by reason of or arising out of any research, investigation, test or analyses or the publication of the results thereof in the name of CEIL. Under no circumstances shall CEIL be liable to the Customer for any indirect, incidental, special or consequential damages of any nature whatsoever (including but not limited to loss of use, revenue, profit, data or business opportunity) either based upon a claim or action in Contract or in Tort, indemnity or contribution, or otherwise arising out of the Contract or performance of services by CEIL even if CEIL has been advised of the possibility of such damages. The limit of CEIL's aggregate liability (whether in Contract, Tort, strict liability in Tort or by statute or otherwise) to the Customer or to any third party for non-performance by CEIL and for any and all other claims shall not in the aggregate exceed the fees paid by the Customer to CEIL. The Customer shall indemnify CEIL against all claims made against CEIL by any third party arising from this Contract.
8. The copyright of any report is reserved to CEIL and it shall not be used either in whole or in part, for the purposes of advertising, publicity, litigation or otherwise without the prior written consent of a duly Authorised Officer of CEIL where such consent is given the Customer shall comply with any conditions attaching to the consent. In conformance with laboratory accreditation requirements reports shall only be produced in full. The test results tabulated shall relate only to the defined item(s) tested.
9. If in CEIL's judgment, the customer's financial condition is such as could adversely affect the customers ability to perform any of its obligations or if the customer is in default in any of its obligations to CEIL whether hereunder or under any other Contract CEIL may terminate this Contract and/ or any other Contract between CEIL and the Customer, cancel any uncompleted order or suspend performance of services or the delivery of any reports and if it does so the Customer shall indemnify CEIL against all costs, charges, expense and damages incurred thereby.
10. CEIL will not be liable for non-performance in whole or in part of its obligations if this is attributable to any cause beyond the control of CEIL including (without limitation) any act of god, force majeure, war, civil war, disturbance, rebellion, embargo, strike, labour dispute, illness, flood, fire, sabotage or government action or regulation. If a Contract or order or any part thereof shall become impossible of performance or otherwise frustrated CEIL shall be entitled to reasonable remuneration for any work done up to the date of such impossibility or frustration, due credit being given for any amounts in respect of the Contract or order paid by the Customer.
11. These Conditions and the Contract to which the document relates shall in all respects be governed by and construed in accordance with the laws of the Republic of Ireland and in accordance with the Republic of Ireland shall have exclusive jurisdiction to determine any disputes arising therefrom unless otherwise agreed.

CONTENTS

- Section 1: Equipment Under Test (E.U.T.)
- Section 2: Test Specification, Methods and Procedures
- Section 3: Operation of E.U.T. During Testing
- Section 4: Results
- Section 5: Analysis of Test Results, Conclusions

- Appendix 1: Test Equipment Used
- Appendix 2: Test Configuration

Test of: Samaritan PAD (Public Access Defibrillator) to:

**EN 60601-1-2: 2002 & EN 55011: 1998 + A2: 2002
(Applicable parts of)**

1 Equipment Under Test (EUT)

1.1 Identification of EUT

Brand Name:	Heartsine
Description:	Samaritan PAD
Country of Manufacture:	Northern Ireland

1.2 Description of EUT

The EUT was a portable battery operated automated defibrillator.

1.3 Modifications

There were no modifications incorporated in the EUT

1.4 Support Equipment

Brand Name:	Heartsine
Description:	Patient Simulator
Model Number:	Samaritan AED Simulator
Country of Manufacture:	Northern Ireland

1.5 Date of Test

The tests were carried out on the 25th and 26th of June, 2007

2 Test Specification, Methods and Procedures

2.1 Emissions Test Specification

Radiated Emissions

EN 55011: 1999 + A2: 2001

Title:

Industrial, scientific and medical (ism) radio-frequency equipment - radio disturbance characteristics - limits and methods of measurement

2.2 Immunity Test Specification

Immunity was assessed to the following standard as requested by the manufacturer:

EN 60601-1-2: 2002

Title: Medical Electrical Equipment

Section 1.2: Collateral standard: Electromagnetic Compatibility – Requirements and tests.

EN 61000-4-2: 2001	Electromagnetic Compatibility (EMC) Part4: Testing and measurement techniques Section 2: ElectroStatic Discharge test
EN 61000-4-3: 2002	Electromagnetic Compatibility (EMC) Part4: Testing and measurement techniques Section 3: Radiated, radio-frequency, electromagnetic field immunity test
EN 61000-4-8: 2001	Electromagnetic compatibility (EMC) Part 4. Testing and measurement techniques. Section 8: Power frequency magnetic field immunity test

2.3 Purpose of test

To determine compliance with the EU EMC Directive 2004/108/EC.

3 Deviations or Exclusions from the Test Specifications

3.1 Deviations

There were no deviations from the test specification.

3.2 Exclusions

There were no exclusions from the test specification.

4 Operation of EUT During Testing

4.1 Operating Environment

The following were the conditions at the time of immunity testing.

Temperature: 21°C
Humidity: 44% RH

4.2 Operating Modes:

The EUT was tested by connecting it to the patient simulator in analysis mode.

5 Results

5.1 Radiated Emissions

Compliant measurements of radiated emissions were carried out on an open area test site from 30 MHz to 1 GHz. The equipment and cable orientation were investigated to ensure that maximum emissions were obtained at critical frequencies. The antenna height was also adjusted through the range of 1m - 4m.

The receiver bandwidth was set to 120 kHz for frequencies between 30 MHz and 1 GHz. See Table 1, Appendix 3 for results.

5.1.1 Measurement Uncertainty

The measurement uncertainty (with a 95% confidence level) for the radiated emissions test was ± 5.3 dB (from 30 to 100 MHz), ± 4.7 dB (from 100 to 300 MHz) and ± 3.9 dB (from 300 to 1000 MHz).

5.2 Electrostatic Discharge Test

Port:	Enclosure
Basic Standard:	EN61000-4-2: 2001
Performance Criterion:	B
Limit:	2,4 & 6 kV contact discharges 2,4,6 & 8 kV air discharges

The ESD generator contained a discharge capacitor of 150pF and resistor of 330Ω in accordance with the requirements of EN61000-4-2: 2001. The tests were carried out using both positive and negative discharges.

Only conductive parts of the equipment that can be touched during normal operation were subjected to contact discharges.

Air Discharges of 2, 4, 6 & 8kV were applied to the EUT. No discharges took to the EUT. 10 contact discharges of each polarity were applied to the vertical coupling plane on all four sides of the EUT. 10 contact discharges of each polarity were also applied to the horizontal coupling plane.

The EUT maintained normal operation during the ESD testing and was subsequently found to be operating satisfactorily.

5.3 Immunity to Radiated, Radio Frequency Electromagnetic Fields

Measurements were performed according to EN61000-4-3: 2001 from 80 MHz to 2500 MHz.

Port: Enclosure
Performance Criterion: A
Limit: 10 V/m
Frequency range: 80-2500 MHz (Modulation: 80% AM 1kHz & 2Hz)
Dwell time: 3 seconds

The EUT was placed in the anechoic chamber.

The step sizes from 80-2500 MHz were in 1% steps. The dwell time at each frequency was 3 seconds. The test level was maintained at over 10 V/m at all frequencies in accordance with clause 36.202.3 a.) 2) of EN 60601-1-2: 2001.

The EUT was in normal running mode during the test.

A field sensor was placed in close proximity to the system. The distance of the antenna from the E.U.T. was 2.2 metres. The tests were carried out with the antenna oriented in horizontal and vertical polarisations.

During the tests the monitor was remotely observed with a CCTV camera to assess any errors in the operation of the EUT.

Frequency MHz	Polarisation (V/H)	Level (V/m)	Result
80-2500 MHz	V and H	10	Complied

Results of Radiated Immunity Tests

5.4 Power Frequency Magnetic Field Immunity Test

Basic Standard: IEC 61000-4-8: 2001
Performance Criterion: A
Level: 3 A/m

The unit was placed on a non-conductive table of 0.8 meter height from the ground plane.

The current level was set to 3 A/m and the unit was centred in the middle of the loop. The EUT was tested with the loop in both horizontal and vertical positions for one minute.

During the tests the E.U.T. was visually observed to assess any disturbance.

The E.U.T. was found to be operating satisfactorily during and subsequent to testing.

See Appendix 2 for the test configuration.

6 Analysis of Test Results, Conclusions

6.1 Measurement Uncertainties

The measurement uncertainties stated were calculated in accordance with the requirements of CISPR 16-4 with a confidence level of 95%.

6.2 Radiated Emissions

The E.U.T. complied with the Class A radiated emission specification by a margin of greater than 10 dB.

6.3 Immunity

The EUT complied with the immunity tests carried out to demonstrate compliance with EN 61000-6-1: 2001.

**Appendix 1
Test Equipment Used:**

Instrument	Mftr.	Model	Serial No.
Bilog Antenna	CEI	699	699
Horn Antenna	EMCO	3115	9905-5809
Signal Generator	Rohde & Schwarz	SME 03	DE24204
Power Amplifier	Milmega	ASM1000-75R	981440
Field Monitor System	Amplifier Research	FM2000	13142
Field Probe	Amplifier Research	FP2000	13130
OPHIR Power Amplifier	OPHIR	5141	713
Signal Generator	Rohde & Schwarz	SMH	883739 /044
Electrostatic Discharge Simulator	Schaffner	NSG432	00978
Positive Discharge Adapter	Schaffner	402 628	9318
Negative Discharge Adapter	Schaffner	402 645	9325
TWT Amplifier	Varian	VZS6950K1	5757
Signal Generator	Hewlett Packard	8672A	R4520S
Transient Simulator	Schaffner	Best Plus	199749A016SC
Magnetic Loop	CEI	-	-

**Appendix 2
Test Configuration:**




Figure 1: Radiated Immunity test



Figure 2: ESD Test



Figure 3: Power frequency magnetic field immunity test



Figure 4: Radiated Emissions test